



Facilities Division

Office: (541) 766-6821
Fax: (541) 766-6891
360 SW Avery Ave
Corvallis, OR 97333
bentoncountvor.gov

ADDENDUM NO. 2
TO THE
CONTRACT DOCUMENTS
FOR
REQUEST FOR PROPOSAL #2325-13
4185 SW RESEARCH WAY HVAC REPLACEMENT PROJECT

April 23, 2024

To ALL Planholders:

The following changes, additions and/or deletions are hereby made a part of the Contract Documents as fully and completely as if the same were fully set forth therein:

- One of the attendees from the pre-bid site walkthrough that occurred on April 17th, 2024 posed two additional questions to the project manager, the questions and answers are described below.

ADDITIONAL:

1. **Do all of the subject units require economizers:**
Yes, regardless of code, all units must have economizers.
2. **Will all thermostats be replaced:**
Yes, but this will be included in the variable air volume (VAV) portion of the solicitation. Project manager is aware that thermostat replacement is necessary for building controls.

All bidders shall acknowledge receipt and acceptance of this Addendum by signing in the space provided and submitting the signed Addendum with the Bid. Bids submitted without this Addendum will be considered informal.

Receipt acknowledged and conditions agreed to this 23rd day of April, 2024.

Bidder _____

By _____